



Certificate of Approval

Certificate No.: SAA100905

Date of Issue: 17 August 2010

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC Guide 65 certifies that the electrical product described on this certificate complies with the minimum safety requirements for which the application has been made.

Certificate Holder: Sungrow Power Supply Co., Ltd.
No. 2, Tianhu Road
New & High Technology Development District
Hefei, Anhui
China

Class Description: Non-Declared
Product Description: Grid-Connected Inverter
Brand Name: Sungrow
Model No.: SG2K5TL
Markings: Input: 150-450V dc 15A Max Class I IP20
Output: 230V ac 50/60Hz 2500W
Standard: AS/NZS 3100:2009
AS 4777.2:2005
AS 4777.3:2005
Conditions: Nil

Approval Mark: SAA100905

Date First Registered: 17 August 2010
Date of Expiry: 17 August 2015

A handwritten signature in black ink, appearing to be 'D', is written over a horizontal red line.

For and on Behalf of
SAA Approvals Pty Ltd



JAS-ANZ

